

Part 1 General**1.1 Summary**

- .1 Unless otherwise indicated, follow the standards below when specifying ceramic tiling work. These standards are not intended to restrict or replace professional judgment.

1.2 Design Requirements

- .1 Recycled content ceramic tile is preferred.
- .2 Laboratories: ceramic tile flooring is not acceptable for laboratories.
- .3 Animal Facilities: Ceramic tiles are not an acceptable wall finish for animal facilities.

Part 2 Products**2.1 Preferred Products**

- .1 Refer to MAT website (www.materialanalysis.ca) for selection of products for this section, except for prescribed items. Products selected on MAT should have score of 5 or above.

2.2 Material Requirements:

- .1 Do not request to the general contractor the surplus for replacement.
- .2 Specify ceramic tile for intensive usage and safe for users.
- .3 Saddles: Shall be imported white marble 16 mm thick with bevelled edges.

END OF SECTION 09 30 13